

Test Verification of Conformity

Verification Number: 210902760SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant **CE** mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Qingdao Haier Air Conditioner General Co., Ltd. No.1 Haier Road Hi-Tech Zone, Qingdao City, 266101, P.R. China
Product Description:	Split Type Room Air Conditioner
Ratings & Principle Characteristics:	See Appendix.
Models/Type References:	See Appendix.
Brand Name(s):	Haier
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Caohejing Development Zone, Shanghai 200233, China

Additional information in Appendix.



Signature

Name: Jonny Jing

Position: Operation Director

Date: October 25, 2021

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 210902760SHA-V1.

Factory (ies) Name &
Address:

Qingdao Haier (JiaoZhou) Air Conditioner Co., Ltd.

Haier Industry Park, Haier Road, Jiaozhou City, Qingdao, Shandong Province,
P.R. China

Models/Type References:

Outdoor unit:

Capacity	Model
14k	2U14MEFFRA, 2U40MEFFRA, 2U40S2SM1FA, 2U40S2SM1FA-3
18k	2U18MEFFRA, 2U50MEFFRA, 2U50MEFFRA, 2U50S2SM1FA-3

Indoor unit:

Series	Capacity	Model
50P	18k	AS18PDAHRA, AS50PDAHRA
50J	18k	AS18JDCHRA, AS50S2SJ1FA-3
35P	09k	AS09PBAHRA, AS25PBAHRA,
	12k	AS12PBAHRA, AS35PBAHRA
35J	09k	AS09JBCHRA, AS25S2SJ1FA-3
	12k	AS12JBCHRA, AS35S2SJ1FA-3
New 25T	09k	AS09TAEHRA, AS25THMHRA-C,
	12k	AS12TAEHRA, AS35TAMHRA-C

Ratings & Principle
Characteristics:

220-240V~, 50Hz, Class I, R32, outdoor unit: IPX4, T1

For the units of 14k: 8,2A, 1,8kW, R32/1,0kg

For the units of 18k: 9,2A, 2,1kW, R32/1,1kg



Signature

Name: Jonny Jing

Position: Operation Director

Date: October 25, 2021

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 210902760SHA-V1.

Frequency Range:	2400-2483.5MHz
Output Power:	≤ 20dBm
Antenna:	PCB Antenna, -4.0dBi
Power Supply:	230V, 50Hz
Network Interface:	802.11/b/g/n
Duty Cycle:	≤ 100%
Applied Directive:	Radio Equipment Directive (2014/53/EU)

Applied Standards &
Test Report Number(s):

Article of RED	Standard	Test Report No.
Article 3.1 a): Safety	EN 60335-1:2012 +A11:2014 +A13:2017 +A1:2019 +A2:2019 +A14:2019 EN 60335-2-40:2003 +A11:2004 +A12:2005 +A1:2006 +A2:2009 +A13:2012 EN 62233:2008	210502081SHA-001
Article 3.1 a): Health	EN IEC 62311:2020	210902760SHA-003
Article 3.1 b): EMC	EN 55014-1:2017+A11:2020, EN 55014-2: 2015, EN IEC 61000-3-2:2019, EN 61000-3-3:2013+A1:2019, EN 301 489-1 V2.2.3, EN 301 489-17 V3.2.4	210902760SHA-001 210902760SHA-002
Article 3.2: Radio Spectrum	EN 300 328 V2.2.2	210902760SHA-004 SHEM200500402604 SHEM2009007992CR 4842020233500B



Signature

Name: Jonny Jing

Position: Operation Director

Date: October 25, 2021

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.